



PLUMBING, HEATING & AIR CONDITIONING

210-655-5112 * 830-609-5112

11326 I.H. 35 North * San Antonio, Texas 78233

WWW.ARNOLDMOOS.COM

Customer Name: _____

Street, City, Zip: _____

Home # _____ Work # _____

Date: _____ Tech: _____

LICENSE # TACL002795C

COOLING INSPECTION

Good	Poor	Needs Repairs	Brand: Model:
			Thermostat
			Filter (<u> X </u>)(<u> X </u>)
			Run Capacitor Rated _____ Actual _____
			Balance of Blower Wheel
			Condition of Blower Wheel (Dirty)
			Condition of Blower Motor
			Amps On Blower Rated _____ Actual _____
			Power Cord and Plug
			Wiring and Connections (Indoor and Outdoor)
			I.D. Unit Supply Voltage _____ Volts
			Evaporator Coil
			Temperature Split _____
			Total Static Pressure _____ "w.c. *Normal Static Pressure .45 to .60
			Drain Line
			Safety Switch or Float Switch or N/A
			Duct Work Condition
			O.D. Unit Supply Voltage _____ Volts
			Disconnect
			Breaker Actual _____ Rated _____
			Refrigerant Head _____ Suction _____
			Line Temp _____
			Saturation _____
			Subcool _____ Superheat _____
			Compressor Amps Rated _____ Actual _____
			Com. Run Capacitor Rated _____ Actual _____
			Condenser Fan Motor and Blade
			Cond. Fan Motor Rated _____ Actual _____
			Cond. Run Capacitor Rated _____ Actual _____
			Start Kit
			Starting Amps on Comp. Actual _____ LRA _____
			Contactors Points
			Condensing Coil
			Electrical Conduit
			Insulation of Refrigerant Line
			Condenser Level



Repair Recommendations:

Estimated Costs:

Arnold Moos Company provides this inspection to identify the cooling equipment condition and/or problems. Any repairs made by Arnold Moos Company will be guaranteed. Any damages that arise from non repaired items will be the customer responsibility.

_____ Customer Signature